

The following example illustrates the basic sizing of a single-stage mixed sludge mesophilic anaerobic digester for a 37,800 m³/d activated sludge municipal wastewater treatment plant.

Design parameters:

Primary sludge:

Solids (TS) produced : 5443 kg/d

TS concentration : 5%

Specific gravity : 1.02

Volatile solids (VS) % : 65%

Thickened waste activated sludge (WAS):

TS produced : 2722 kg/d

TS concentration : 4%

Specific gravity : 1.00

VS % : 75%

Calculations

1. Daily sludge volume:

$$\text{Sludge Volume} = \frac{\text{TS produced}}{\text{Specific gravity} * \text{Density of water} * \text{TS concentration}}$$

$$\text{Primary Sludge Volume} = \frac{5443 \text{ kg/d}}{1.02 * 1000 \text{ kg/m}^3 * 0.05} = 106.7 \text{ m}^3/\text{d}$$

$$\text{Thickened WAS Volume} = \frac{2722 \text{ kg/d}}{1.00 * 1000 \text{ kg/m}^3 * 0.04} = 68 \text{ m}^3/\text{d}$$

$$\text{Total Sludge Volume} = 106.7 + 68 = 174.7 \text{ m}^3/\text{d} (\approx 175 \text{ m}^3/\text{d})$$

2. Digester Volume:

Assume → SRT = HRT = 15 d

$$\text{Digester Volume} = Q * \text{HRT} = 175 \text{ m}^3/\text{d} * 15 \text{ d} = 2625 \text{ m}^3$$

3. Solids Loading Rate:

Total VS produced = (Primary sludge produced * VS %) + (WAS produced * VS %)

$$\text{Total VS produced} = (5443 \text{ kg/d} * 0.65) + (2722 \text{ kg/d} * 0.75) = 5579 \text{ kg/d}$$

$$\text{VS Loading Rate} = \frac{\text{VS produced}}{\text{Digester Volume}} = \frac{5579 \text{ kg/d}}{2625 \text{ m}^3} = 2.12 \text{ kgVS/m}^3 \cdot \text{d}$$

4. Digester Sizing:

Assume → 2 cylindrical digesters with 15 m diameters

$$\text{Active Volume of each Digester} = \frac{2625 \text{ m}^3}{2} = 1312 \text{ m}^3$$

$$\text{Surface Area} = \frac{\pi * D^2}{4} = 176.7 \text{ m}^2 \approx 177 \text{ m}^2$$

$$\text{Active Depth} = \frac{\text{Volume}}{\text{Surface Area}} = \frac{1312 \text{ m}^3}{177 \text{ m}^2} = 7.4 \text{ m}$$


Additional depths for:

- Grit deposit (in addition to conical bottom) = 0.5 m
- Scum blanket = 0.5 m
- Space below cover = 1.0 m

Total additional depth = 0.5 m + 0.5 m + 1 m = 2.0 m

Total Side-wall Depth = 7.4 + 2.0 = 9.4 m

5. VS Reduction and Biogas Production:



Assume → 55% VS removal at 15 days SRT under mesophilic conditions

$$\text{VS removed} = \text{VS loading} * \text{VS removal efficiency} = 5579 \text{ kg/d} * 0.55 = 3068 \text{ kg/d}$$

Assume → 1.0 m³ biogas production/ kg VS removed

$$\text{Total Biogas Produced} = \text{VS removed} * 1 \text{ m}^3/\text{kg} = 3068 \text{ m}^3/\text{d}$$

Assume → 65% CH₄ in biogas

$$\text{Total CH}_4 \text{ produced} = \text{Total biogas produced} * 0.65 = 1994 \text{ m}^3/\text{d}$$

Assume → Lower heating values of CH₄ = 35,800 kJ/m³ and 1 W = 1 J/s

$$\text{Heat capacity of total CH}_4 \text{ produced} = 1994 \text{ m}^3/\text{d} * 35800 \text{ kJ/m}^3 = 82.6 \text{ kW}$$

6. TS in Digested Sludge

Fixed Solids = Total Solids – Volatile Solids

Fixed solids = (Primary sludge + WAS) – Total VS

$$\text{Fixed solids} = (5443 \text{ kg/d} + 2722 \text{ kg/d}) - 5579 \text{ kg/d} = 2586 \text{ kg/d}$$

$$\text{VS remained after digestion} = \text{Total VS} - \text{VS removed} = 5579 \text{ kg/d} - 3068 \text{ kg/d} = 2511 \text{ kg/d}$$

$$\text{TS in Digested Sludge} = \text{Fixed solids} + \text{VS remained} = 2586 + 2511 = 5097 \text{ kg/d}$$

Assume → Specific gravity of digested sludge = 1.02

$$\text{TS \%} = \frac{\text{TS in Digested Sludge}}{1.02 * 1000 \text{ kg/m}^3 * \text{Sludge Volume}} = 0.285 = 2.85\%$$

7. Digester Heating

Assume → Temperature conditions:

Ambient air	= 5 °C
Earth around wall	= 7 °C
Earth below floor	= 12 °C
Raw sludge feed	= 15 °C
Digester contents	= 35 °C

Assume → Heat transfer coefficients, U:

Insulated wall exposed to air	= 0.70 W/m ² .°C
Wall exposed to dry earth	= 0.62 W/m ² .°C
Moist earth below floor	= 0.85 W/m ² .°C
Insulated cover (roof)	= 0.95 W/m ² .°C

$$\text{Volume of sludge fed to each digester} = \frac{175 \text{ m}^3/\text{d}}{2} = 87.5 \text{ m}^3/\text{d}$$

Compute heat required for each digester for raw sludge using equation

$$Q_1 = W_f \cdot C_p \cdot (T_1 - T_2)$$

Q_1 heat required, J/d

W_f feed sludge weight (density of sludge * volume), kg/d

C_p specific heat of sludge (assumed to be same as water), 4200 J/kg · °C

T_2 design operating temperature of digester, °C

T_1 temperature of feed sludge, °C

Assume → Density of sludge = 1000 kg/m³

$$\begin{aligned} \text{Heat required for sludge } (Q_1) &= (1000 \text{ kg/m}^3 * 87.5 \text{ m}^3/\text{d}) * 4200 \text{ J/kg} \cdot \text{°C} * (35-15) \text{ °C} \\ &= 73.5 * 10^8 \text{ J/d} \end{aligned}$$


$$\text{Wall area of each digester} = \Pi * \text{Diameter} * \text{Total depth} = 443 \text{ m}^2$$

Assume → ½ of the wall is below ground

$$\text{Areas exposed to dry earth or air} = \frac{443 \text{ m}^2}{2} = 221.5 \text{ m}^2$$

Center depth (h) of conical tank floor at a slope of 1:5 = 1.5 m

$$\text{Floor area exposed to earth} = \Pi * r * s = 180.3 \text{ m}^2$$



$$\text{Flat fixed cover (roof) area} = \Pi * r^2 = 176.6 \text{ m}^2$$

Compute the heat loss for each component using equation

$$Q_2 = U \cdot A \cdot (T_2 - T_3)$$

Q_2 heat loss, J/s

U heat transfer coefficient, J/m²·s·°C

A surface area of digester through which heat losses occur, m²

T_2 temperature of sludge in digester, °C

T_3 temperature outside the digester, °C

$$\begin{aligned}
\text{Wall above ground (exposed to air)} &= 0.70 \text{ W/m}^2 \cdot ^\circ\text{C} * 221.5 \text{ m}^2 * (35-5)^\circ\text{C} = 4652 \text{ W} \\
\text{Wall below ground (dry earth)} &= 0.62 \text{ W/m}^2 \cdot ^\circ\text{C} * 221.5 \text{ m}^2 * (35-7)^\circ\text{C} = 3845 \text{ W} \\
\text{Floor (exposed to moist earth)} &= 0.85 \text{ W/m}^2 \cdot ^\circ\text{C} * 180.3 \text{ m}^2 * (35-12)^\circ\text{C} = 3525 \text{ W} \\
\text{Cover (roof exposed to air)} &= 0.95 \text{ W/m}^2 \cdot ^\circ\text{C} * 176.6 \text{ m}^2 * (35-5)^\circ\text{C} = 5033 \text{ W}
\end{aligned}$$

$$\text{Total Heat Loss} = 17055 \text{ W} = 17055 \text{ J/s} = 14.7 * 10^8 \text{ J/d}$$

Compute the required heat exchanger capacity for each digester:

$$\begin{aligned}
\text{Heat Capacity Required} &= \text{Heat required for sludge} + \text{Heat lost in digester} \\
&= (73.5 + 14.7) * 10^8 \text{ J/d} \\
&= 88.2 * 10^6 \text{ J/d (single heat exchanger for raw+recirculating sludge)}
\end{aligned}$$

If separate heat exchangers are used for heating raw sludge feed and the recirculating sludge, the heat exchanger capacities should be $3.38 \times 10^7 \text{ J/h}$ and $7.78 \times 10^7 \text{ J/h}$, respectively.